	Launury	
a	Is It Adequate	Yes
b	Modern Equipment	708
C	Drier	Tes
)	Boilers	
2	Number	240
ъ	Condition	Good
1	Transformers	200
a	Properly Housed	Suspended on poles.
b	Properly Screened	
2	Storage	
a	Structure, Type & Number	4 two-story wooden 3 One-story wooden
b	Gas and DDT	Tes
C	Garage	708
13	water Supply	
a	Source	C1ty
b.	Tested	Tes
	Security Features	
1	Wall or Fence, Materials	Concrete coated adobe wall
a	Height and Condition	4 meters - good

I A 1 a (1)		
2	Locking System	Standard
3	Type and Size of Cells	Ranging from 2 tsube single cell to 3.5 tsube
4	Armory	
a	Location	Chief of Custody Office
b	Adequate Security	You
c	Type and Number of Weapons	24 Pistols O Rifles
(1)	Condition	All serviceable
	Ammunition, Type & Amt	1994 Pds Pistols Rds Rifles
D	Kitchen	
1	Facilities and Equipment	Adequate
2	Sanitation	Satisfactory
3	Doors and Windows Screened	Tee
E	Food Storage	Yes - two
1	Type of Building	One floor - wooden

Declassified	
E. 0.	
12065	
Section	
3-402/NNDC	
NO.	
11/500	1

-

		Ammunition, Type & Amt	1994 Pds Pistols Rds Rif	'le
	D	Kitchen		
	1	Facilities and Equipment	Adequate	
	2	Sanitation	Satisfactory	
	3	Doors and Windows Screened	Tes	
	E	Food Storage	Tes - two	
	1	Type of Building	One floor - wooden	
	2	Type of Floor	Concrete	
	3	Are Windows & Doors Screened	Yes	
	4	Is It Rat Proof	700	
	5	Cleanliness	Satisfactory	
	F	Fire Equipment		
	1	Type and Number	1 gasoline pumper 3 large manual operated pumpers	
•			2 small 14 chemical fire extinguishers	
	2	Condition	Good	
	3	Number of Static Pools and/or Hydrants	Three static mater poels Two hydrants	

400

.

a	Volumes	Adequate
4	Periodical Inspections	Three static water pools Two hydrants
5	Written Fire Plan	Yos
a	Coordinated with Local FD	Yes
6	Frequency of Fire Drills	Twice each month
7	Fire Marshal Graduate of Central Fire School, Tokyo	Yes
III	WARDEN'S COMMENTS AND REMARKS	(1) Needs 46 pistols and 30 riot guns. (2) Cottom batting and 67,000 yards of cloth for institional use. (3) Budget to install two hot water pipes throughout cell blocks as a heating unit. (4) 600 yards of guard uniform material. (5) Increase in prison official salaries. (6) 5000 additional books for library. (7) Three additional guard towers and 10 flood lights. (8) One piane for immate recreation. (9) Budget to construct a 80-tsube calisthenics room.
X	CONCLUSIONS	It is the opinion of PSD Rep. that Warden S. Kikuchi is capable of performing the functions required of him. However, with the exception of two or three staff officers, said staff is weak and inefficient, particularly the academic, vocations, and industrial programs.

CONCLUSIONS

RECOMMENDA TIONS

600 yards of guard uniform material. Increase in prison official salaries.

50000 additional books for library. (7) Three additional guard towers and

10 flood lights.

(8) One piane for immate recreation. (9) Budget to construct a 80-tsube

calisthenies room.

It is the opinion of PSD Rep. that Warden S. Kikuchi is capable of performing the functions required of him. However, with the exception of two or three staff officers, said staff is weak and inefficient, particularly the academic, vocations, and industrial programs.

(1) Concur with warden's request. (2) That the new inspection forms be used in future inspections. (Investigation will be made as to why Magane has not been supplied new forms).

(3) As soom as possible, the old hospital be rased and a new one be constructed.

(4) That all machinery and equipment listed in this report as needed be provided.